

Vuba Building Products Ltd.
Units B2-B4,
Grovehill Industrial Estate,
Annie Reed Road,
Beverley
HU17 0LF

Date: 24 August 2020
Test Report Ref: TR 747820

Page 1 of 1

Contract: Vuba Building Products Ltd

LABORATORY TEST REPORT

TEST REQUIREMENTS:

To determine the Particle Density and water absorption for aggregate sample between 4 mm and 31.5mm, in accordance with **BS EN 1097-6: 2013 Clause 8**

SAMPLE DETAILS:

Certificate of sampling received:	No
Laboratory Ref. No:	S89382
Client Ref. No:	Nero
Date and Time of Sampling:	Unknown
Date of Receipt at Lab:	12/08/2020
Date of Start of Test:	20/08/2020
Sampling Location:	Unknown
Name of Source:	Unknown
Method of Sampling:	Unknown
Sampled By:	Client
Tested By:	JH
Material Description:	Fine Aggregate
Target Specification:	N/A

RESULTS:

Particle density on an oven-dried basis =	2.79 Mg/m ³
Particle density on a saturated and surface-dried basis =	2.80 Mg/m ³
Apparent Particle density =	2.82 Mg/m ³
Water absorption (of dry mass) =	0.4%

This test report shall not be reproduced, except in full, without the written approval of Celtest Company Limited.

These results relate only to the items tested.

<u>Comments:</u> None	Report checked and approved by:  Joseph Parry Aggregate Team Coordinator
---------------------------------	---