

Vuba Building Products Ltd.
Units B2-B4,
Grovehill Industrial Estate,
Annie Reed Road,
Beverley
HU17 0LF

Date: 10 September 2020
Test Report Ref: TR 747832

Order No: Bank Transfer

Page 1 of 1

Contract: Vuba Building Products Ltd

LABORATORY TEST REPORT

TEST REQUIREMENTS:

To determine the Fragmentation of Aggregate - Los Angeles
Test Method in accordance with **BS EN 1097-2: 2010 - Annex B**

SAMPLE DETAILS:

Certificate of sampling received:	No
Laboratory Ref. No:	S89382
Client Ref. No:	Tuscan
Date and Time of Sampling:	Unknown
Date of Receipt at Lab:	12/08/2020
Date of Start of Test:	09/09/2020
Sampling Location:	Unknown
Name of Source:	Unknown
Method of Sampling:	Unknown
Sampled By:	Client
Tested By:	WK
Material Description:	Fine Aggregate
Target Specification:	N/A

RESULTS:

Size fraction from which the test portion was obtained: 4mm to 8mm
6.3mm to 4mm

Los Angeles Coefficient (LA) = 25

This test report shall not be reproduced, except in full, without the written approval of Celtest Company Limited.

These results relate only to the items tested.

Comments: None	Report checked and approved by:  Joseph Parry Aggregate Team Coordinator
--------------------------	--